

NOTES

Gully

- The minimum depth from the top of the grating to the top of the gully outlet is to be 750mm, cover to outlet required when under carriageway.
- 2. Depth of gully pot to be 900mm in primary and secondary roads and, 750 mm in tertiary and shared surface roads.

Grating and Frame

- 3. To be D400 double triangular or hinged as required by the SCC.
- 4. Gully frame to be set 5-10mm below carriageway surface.
- Precast concrete riser units are to be used. Reinstatement to be proprietary mastic asphalt or HRA as agreed with SCC.
- 6. Rodding eye to have stopper and chain installed.



Growth, Highways & Infrastruture Suffolk County Council Endeavour House 8 Russell Road Ipswich Suffolk IP1 2BX

DRAWING TITLE

DRAINAGE AND SERVICE DUCTS
PRECAST GULLY WITH SIDE ENTRY

	REV.	DESCRIPTION	CHECKED	DATE
	Α	MINOR CHANGES IN NOTES	СВ	10/2025

	INIT.	DATE	PROJECT TITLE		
ORIGINATOR	RY	08/2024	STANDARD CONSTRUCTION DETAILS		
CHECKER	SH	08/2024	SCALE	DATE	
DESIGNER	RY	08/2024	N.T.S. DRAWING No.	AUG. 2024	
REVIEWER	TK	08/2024	DM-500-04A		

ORIGINAL SIZE: A4