




NOTES

1. Trees and hedge may be planted in slopes adjacent to swales without underdrains subject to appropriate soil properties, species selection and root protection agreed in writing with SCC – See Suffolk Design guide for tree in Highways.
2. Area adjacent to carriageway to be constructed with 100 x 100 x 100mm granite setts on a Class 3 mortar bed 50mm thick with Class 3 12mm wide mortar joints to capture silt/debris from carriageway.
3. Area to be extended to 1m to allow for street lighting.
4. Topsoil 150mm thick with turf or planting as permitted design.
5. Inspection chamber to be at designed at 70m centres and connected into surface water system.
6. Swale design to align with National & LLFA guidance: longitudinal slopes should be 0.5–6% (1:33) unless specific site/safety arrangements allow for alternative criteria. Check dams needed if gradient steeper than 0.5–6% (1:33).
7. Minimum length of swale to be 5m.
8. Perforated pipe should be elevated in infiltration structures to ensure it does not convey flow during 1:1+CC rainfall event.
9. Type B material can be replaced by bio-retention material for greater treatment of surface water but overflow will need to be designed at a level to be agreed with SCC and LLFA.



Growth, Highways & Infrastructure
Suffolk County Council
Endeavour House
8 Russell Road
Ipswich
Suffolk IP1 2BX

DRAWING TITLE

DRAINAGE AND SERVICE DUCTS
SURFACE WATER SWALE CHUTE

REV.	DESCRIPTION	CHECKED	DATE

INIT.	DATE	PROJECT TITLE