


NOTES

- 1. Dimension X is the external diameter of the pipe.
- 2. Type Z concrete is to extend full width of trench unless shuttered.
- 3. Minimum pipe diameter to be 450mm.
- 4. Minimum cover from the access surface to top of concrete surround to be 600mm.
- 5. Refer to drawing nos. DM-500-12 to 14 for the headwall details.
- 6. Refer to the SCC standard drawings for access and footway details.





Growth, Highways & Infrastruture Suffolk County Council Endeavour House 8 Russell Road Ipswich Suffolk IP1 2BX DRAWING TITLE

DRAINAGE AND SERVICE DUCTS TYPICAL CULVERT CROSSING

REV.	DESCRIPTION	CHECKED	DATE

	INIT.	DATE	PROJECT TITLE	
ORIGINATOR	RY	09/2025	STANDARD CONSTRUCTION DETAILS	
CHECKER	SH	09/2025		DATE
DESIGNER	RY	09/2025	N.T.S. SEP. 2025 DRAWING No.	
REVIEWER	TK	09/2025		500-25

ORIGINAL SIZE: A4