



KEY

-  Type A filter material to Clause 7.9
-  Type B filter material to Clause 7.9

NOTES

1. All dimensions are in millimetres
2. Dimension X is the external diameter of the pipe.
3. Pipes are to be laid with slots or perforations upwards.
4. Minimum Drain width to be $Y=X+300$ for drains not exceeding 1.5m cover below finished level. $Y=X+450$ for drains exceeding 1.5m cover below finished level.

SUFFOLK COUNTY COUNCIL

Revisions	Date	Inl.	No.	TITLE	Drawn	Ch'd.
New Issue			A	SUB SOIL AND FILTER DRAINS TRENCH AND BEDDING DETAILS	WS	
Title Block Amended	03/04	J.G	B		Ex'd.	App'd.
					Scale	Date
					N.T.S.	5/02
					Drg. No.	7/102B

Director of Environment & Transport